
To: **Town Of Carleton Place**
Attn: Ross Rankin
Project Manager

Location: 75 Neelin Dr, Carleton Place
Carleton Place Arena

Date: 2026-05-27

Reference: 100-2607 – Carleton Place Arena RTU replacement

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification.

Clarifications/Modifications/Additions:

1. Existing electrical connections to RTU-1 and RTU-2 to remain. Replace existing fuses in existing disconnects with new 30A fuses located in main electrical room.
2. Contractor to provide new 5-20R WP service receptacle for each new RTU. Source from closest panel. C/w all conduit and wiring.

END OF ADDENDUM